

Letter No: 261

Officer of the station fire officer, Danapur

From,  
Station Fire Officer  
Danapur

To,  
Dr Neena Kumar (Principal)  
New Era Public School  
Baghakol Faridpur, PO-Patul, P.S-Bikram  
Dist. Patna-801112

Dated: 28/05/2019

Ref.- Your letter no. NEPS/17/19-20 dated: 22-05-2019

Subject: - Regarding fire precautionary measures NOC of New Era Public School  
(School Building);

Sir,

With reference to your letter as mentioned above your premises was inspected by us on dated 23-5-2019. During inspection it was found that your school is situated on Baghakol Faridpur, PO-Patul, P.S-Bikram, Dist. Patna-801112.

This is school building of G+2 (low high rise building). At the time of inspection we found the following:-

1. That the school building has RCC construction, thus it covers the required fire resistance.
2. That the building possesses two stair cases and the class room also possesses two exits, thus it covers the norms.
3. That the school have ISI marked portable fire extinguishers as per norms.
4. That there are sufficient open areas in and around the building that can be used as refuge area at the time of emergency.

We have no objection on the following grounds:-

- i) That evacuation drill be carried out at least twice in a year.
- ii) That fire service emergency number should be hanged at appropriate place.
- iii) That installed fire equipments be maintained as per relevant norms.
- iv) That inbuilt fire protection system be installed as per NBC norms at earliest.
- v) That AMC of the installed equipments be given to a qualified firm so that it can be operated safely at the time of emergency.

This is valid for one year from the date of issue of the letter.

Neena Kumar

Principal  
NEW ERA PUBLIC SCHOOL  
Baghakol Faridpur, P.O.-Patul  
P.S.-Bikram, Distt-Patna  
PIN-801 112

etish Kumar

Manager  
NEW ERA PUBLIC SCHOOL  
Baghakol Faridpur, P.O.-Patul  
P.S.-Bikram, Distt.-Patna  
Pin-801112

Your's faithfully

etish Kumar

28/05/19

(Station Fire officer)

Danapur